太阳能产品认证证书

证书编号：CQC16024148544

申请人名称及地址

爱士惟新能源技术（扬中）有限公司
江苏省扬中市经济开发区港兴路 588 号

制造商名称及地址

爱士惟新能源技术（扬中）有限公司
江苏省扬中市经济开发区港兴路 588 号

生产企业名称及地址

爱士惟新能源技术（扬中）有限公司(V013471)
江苏省扬中市经济开发区港兴路 588 号

产品名称和系列、规格、型号

光伏并网逆变器
Evershine TLC6000、Evershine TLC5000、Evershine TLC4000（见附件）

产品标准和技术要求

NB/T32004-2013（IIIa，不含低电压穿越试验）

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC33-461239-2013 认证规则的要求，特发此证。

发证日期： 2019 年 04 月 02 日

本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2016 年 06 月 30 日

主任：

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070
http://www.cqc.com.cn

T 0012814

SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC16024148544

NAME AND ADDRESS OF THE APPLICANT

AISWEI New Energy Technology (Yangzhong) Co., Ltd
No.588 Gangxing Road,Economic Development Zone,Yangzhong, Zhenjiang, Jiangsu

NAME AND ADDRESS OF THE MANUFACTURER

AISWEI New Energy Technology (Yangzhong) Co., Ltd
No.588 Gangxing Road,Economic Development Zone,Yangzhong, Zhenjiang, Jiangsu

NAME AND ADDRESS OF THE FACTORY

AISWEI New Energy Technology (Yangzhong) Co., Ltd (V013471)
No.588 Gangxing Road,Economic Development Zone,Yangzhong, Zhenjiang, Jiangsu

PRODUCT NAME, MODEL AND SPECIFICATION

PV Grid- on Inverter
Evershine TLC6000、Evershine TLC5000、Evershine TLC4000（See Appendix）

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T32004-2013(IIIa,Without Low Voltage Ride Through Test)

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461239-2013 .

Valid from: Apr.02,2019

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

Date of original issued: Jun.30,2016

President: Lu Mei

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
http://www.cqc.com.cn

T 0012814

太阳能产品认证证书

附　　录　　第 1 页 共 1 页

证书编号：CQC16024148544　　纸　号：12814

Evershine TLC6000
直流输入:MPPT 电压范围 200V-900Vdc,最大直流输入电压 1000Vdc,最大输入电流:11A/11A; 交流输出:3/N/PE～,380V/400V,50Hz,9.2A,额定交流输出功率 6kW;

Evershine TLC5000
直流输入:MPPT 电压范围 200V-900Vdc,最大直流输入电压 1000Vdc,最大输入电流:11A/11A; 交流输出:3/N/PE～,220V/380V,50Hz,8.5A,额定交流输出功率 5kW;

Evershine TLC4000
直流输入:MPPT 电压范围 200V-900Vdc,最大直流输入电压 1000Vdc,最大输入电流:11A/11A; 交流输出:3/N/PE～,220V/380V,50Hz,6.8A,额定交流输出功率 4kW.

注：此附录与证书同时使用时有效。

主任：

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070
http://www.cqc.com.cn