



中国船级社
CHINA CLASSIFICATION SOCIETY

证书编号/Certificate No.
SH20PTB00184

型式认可证书
CERTIFICATE OF TYPE APPROVAL

兹证明本证书所述制造厂具备按照下列标准的要求生产本证书所列产品的能力和条件。

This is to certify that the manufacturer stated in the certificate meets the requirements of the standards listed below and is available with the ability and conditions to produce the products described in the certificate.

制造厂/Manufacturer

维梯埃消防设备(上海)有限公司
VTI FIRE PRODUCTS(SHANGHAI)CO.,LTD.

地址/Address

上海市浦东新区合庆镇东川公路5237号5楼
Floor 5, No.5237, Dongchuan Highroad, Heqing Town, Pudong New District, Shanghai

产品名称/Product

自动喷水器灭火系统
Automatic Sprinkler Fire-extinguishing System
自动喷水器
Automatic Sprinkler System

认可标准/Approval Standard

- 1. 1974《国际海上人命安全公约》及其修正案第II-2章第10条
Regulation 10,ChapterII-2 of International Convention for the Safety of Life at Sea,1974
- 2. 经MSC. 327(90)和MSC. 339(91)修正的《国际消防安全系统规则》第8章
Chapter8 of International Code for Fire Safety System,as Amended by MSC.327(90)and MSC.339(91)
- 3. A. 800(19)《经修订的与SOLAS 公约II-2/12 条规定等效的喷水器系统认可指南》及其MSC. 265(84)、MSC. 284(86)修正案
Resolution A.800(19) Revised Guidelines for Approval of Sprinkler Systems Equivalent to that Referred to in SOLAS Regulation II-2/12,and as Amended by MSC.265(84), MSC.284(86).

用于/Intended for

船舶与海上设施/Ships and Offshore Installations

产品明细/Product Description

自动喷水器/Automatic Sprinkler System (M0001)

名称/Name	属性(值)/Value	单位/Unit
型号/Type	见附页/See additional page	
设计压力/Design Pressure	见附页/See additional page	Mpa
系统工作方式/Operation Method of System	见附页/See additional page	
喷头型号/Nozzl Model	见附页/See additional page	

证书有效期至/ This Certificate is valid until 2023年07月21日/ Jul. 21,2023

发证机构/Issued by 中国船级社上海分社
CCS Shanghai Branch

签发日期/Date 2020年10月26日
Oct. 26,2020

本证书根据中国船级社规范和相关规定签发。所有证书页为一个整体,必须同时使用。纸质证书每页均须由本社盖章方为有效,电子证书含数字签名方为有效,本证书复印件无效。任何单位和个人不应摘录或节选本证书的部分内容。有关方对所持证书的真实性有疑问时,可以向本社检验机构咨询。This Certificate is issued pursuant to the Rules of the Society and related regulation. All pages of the certificate are taken as a whole and are used simultaneously. No paper certificate page is valid without bearing the stamp of the Society, no electronic certificates is valid without the digital signature, and no copied form of the certificate is regarded as valid. Any part of the certificate is not to be extracted or abridged by any unit or individual in any form. Related parties who are doubted about the authenticity of the certificate may inquire of the Society or its offices.



Form No: T01.

联系方式/Contact Us, 见本社官方网站/See official web site of the Society (<http://www.ccs.org.cn>)

UTN:P020-36395115

持续供水时间/Time Continuous Water Supply	见附页/See additional page	
海水泵扬程/Raise of Sea Water Pump	见附页/See additional page	
海水泵流量/Flow Rate of Sea Water Pump	见附页/See additional page	
压力水柜容积/The Capacity of Pressure Water Tank	见附页/See additional page	

批准的图纸/Approved Drawings

图纸批准号/ Drawings Approval No. : SH20PPP20395

产品认可试验报告/ Approval Test Report

试验报告编号/ Test Report No. : AME08-TP01
 试验报告日期/ Test Report Date : 2019-01-24
 试验单位/ Laboratory: 维梯埃消防设备(上海)有限公司 VTI FIR PRODUCTS (SHANGHAI) CO., LTD.
 试验单位地址/ Test Address: 上海市浦东新区合庆镇东川公路5237号5楼 Floor 5, No.5237, Dongchuan Highroad, Heqing Town, Pudong New District, Shanghai

试验报告编号/ Test Report No. : A19-006-ZC
 试验报告日期/ Test Report Date : 2019-06-24
 试验单位/ Laboratory: 上海仪器仪表自控系统检验测试所有限公司 Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.
 试验单位地址/ Test Address: 上海市漕宝路103号 No.103, Caobao Road, Shanghai

试验报告编号/ Test Report No. : AME08-TP02
 试验报告日期/ Test Report Date : 2020-10-23
 试验单位/ Laboratory: 维梯埃消防设备(上海)有限公司 VTI FIRE PRODUCTS (SHANGHAI) CO., LTD.
 试验单位地址/ Test Address: 上海市浦东新区合庆镇东川公路5237号5楼 Floor 5, No.5237, Dongchuan Highroad, Heqing Town, Pudong New District, Shanghai

认可后的产品检验方式/ Method of Product Inspection after Approval

按规范认可后应进行产品检验的产品/The product should be inspected in term of the rules:
 认可后的产品检验应由本社验船师根据本社规范规定按批准的产品检验计划进行检验, 经检验合格后由本社颁发船用产品证书。

After approval, product inspection should be carried out by the Surveyor of the Society in accordance with the approved product inspection scheme, and the Marine Product Certificate will be issued by the Society upon satisfactory inspection.

认可保持条件/ Maintenance Requirements of Approval

1. 型式认可后, 如果产品及其重要零部件的设计、所用材料或制造方法有所改变, 且影响到产品的主要特性、特征; 或产品的性能指标有所更改, 且超过认可的范围, 则有关图纸和文件应经检验机构审批。并在检验机构认为必要时, 经本社检验人员见证有关试验和进行检查, 其结果应能证实仍符合认可条件。

After type approval, if there are changes to the design, materials used or manufacturing method of the product and important components and such changes affect major characteristics and properties of the product, or property indexes of the product are changed and exceed the scope of approval, related drawings and documents are to be examined and approved by the concerned survey office. Where deemed necessary by the survey office, the surveyor to the Society will go to witness relevant tests and conduct inspection and the results should be able to demonstrate compliance with the approval conditions.

2. 工厂的质量管理体系应保持有效运行, 并且与认可时一致。如果质量管理体系发生改变, 应经原体系认证机构审核并报本社批准。

The quality management system of the factory shall be ensure effective operation, and shall be the same as the situation of approval. If there are any changes to the quality management system, auditing of the original certification organization for quality management system and the society's approval shall be obtained.

3. 认可证书有效期内, 如果出现可能导致本社取消认可的情况, 工厂应及时采取有效的纠正措施。

Within the validity of the approval certificate, if cases occur that may cause the Society to withdraw the approval, the manufacturer should take corrective actions in a prompt and effective manner.

4. 在认可证书有效期内, 本社检验人员可在未经事先通知的情况下对工厂的产品制造过程进行审核, 以验证产品的

生产是否符合业经本社批准的图纸和文件。工厂应予以配合。

Within the validity of the approval certificate, the surveyor to the Society may pay unannounced audit to the manufacturing process of the product in order to confirm whether it is in compliance with the drawings and documents approved by the Society. The factory should provide an active cooperation and necessary for the surveyor.

5. 如果属于获得型式认可B 模式证书，且无需颁发船用产品证书/等效证明文件的情况，证书获得者应接受本社每年一次的定期审核，定期审核日为认可证书期满之日对应的每一周年日，检查工作应在周年日的前后三个月内进行。

If belong to the situation of the product has type approval mode B certificate, and marine product certificate/equivalent document is not necessary, those who have obtained the certificate should be subject to periodical audit every year. The date of periodical audit shall be each anniversary date which corresponds to the date of expiry of the relevant certificate and the periodical audit shall be done within a time span of three months before and after the annual surveillance date.

备注/Remarks

本证书由原型式认可证书（No. SH18T00093）变更并替代原证书。

This Certificate is modified from and supersedes the previous Type Approval Certificate No. SH18T00093.

本社已审核了产品厂无石棉声明，但本社的审核不免除产品厂按照合同关系向订货方保证产品无石棉的责任。

The declaration of asbestos-free submitted by manufacturer has been reviewed by the Society. However, liability of the manufacturer to guarantee the products are asbestos-free to purchaser under contract will not be exempted.

中国船级社上海分社
CCS Shanghai Branch

注：本证书含有附页，共1页

Note: The certificate is attached with additional 1 page(s)

产品明细/Product Description

序号 /No.	名称/Name	技术性能/Technical performance
1	系统型号 (Type):	AME08-1
2	系统设计压力 (Design pressure of system):	0.4-1.2Mpa
3	系统工作方式 (Operation method of system):	自动/Automatic
4	系统灭火介质 (Fire-fighting Medium of system):	淡水/海水 /Fresh water/Sea water
5	系统电源 (System power):	AC 440/380/220V;50/60Hz
6	持续供水时间 (Time continuous water supply):	≥30min
7	(海水泵)扬程/流量/电机功率 (Raise of sea water pump/Flow rate of sea water pump/Power of sea water pump):	扬程/Raise: 按退审图纸参数/According to the approved drawing technical parameters 流量/Flow rate: 按退审图纸参数/According to the approved drawing technical parameters
8	(淡水泵)扬程/流量/电机功率 (Raise of fresh water pump/Flow rate of fresh water pump/Power of fresh water pump):	扬程/Raise: 按退审图纸参数/According to the approved drawing technical parameters 流量/Flow rate: 按退审图纸参数/According to the approved drawing technical parameters
9	压力水柜容积/工作压力 (The capacity of pressure water tank/Work pressure):	容积/Capacity: 按退审图纸参数/According to the approved drawing technical parameters 工作压力/Work pressure: 0.3-1.2Mpa
10	喷头型号 (Nozzle type):	(ZSTZ、ZSTB、ZSTX、ZSTDY)-15/5、15/3-68、79、93
11	喷头最小工作压力 (Nozzle min. working pressure):	0.5 bar
12	区域报警阀型号 (The type of zone alarm valve):	ZAV8-40/50/65/80/100 设计压力 (Design pressure): 1.6Mpa
13	湿式报警阀型号 (The type of wet alarm valve):	ZSFZ-100/150/200 设计压力 (Design pressure): 1.6Mpa
14	电气设备 (泵主控制箱) (Main control box of sea water & fresh water pump):	防护等级 IP54 (Protection grade: IP54)